

PROGRAMMABLE PUMP CONTROLS

PPC5001 • PPC5002 • PPC5003



Accurate, reliable and durable controllers are just as important in your water treatment equipment system as are the accurate, reliable and durable water meters. Carlon's Programmable Chemical Pump Controls with an LCD display are suitable for all types of applications where feeding the chemicals in proportion to water use is desired. PPC series Pump Controls include both a programmable predetermining counter for counting the impulses received from an electric contacting meter and a programmable timer for operating the Chemical Feed Pump/Valve for the desired length of time. Each timer has its own predetermining counter. All counters and timers are programmable as required by the application. Light emitting diodes indicate when the timer(s) is activated. Programmable options included with all models are sequential, or simultaneous, or minutes. Or seconds, and historical tracking of input pulses to the controller.



1710 EATON DRIVE • GRAND HAVEN, MICHIGAN 49417

PHONE (616) 842-0420 • FAX (616) 842-1265

E-MAIL CARLON@CARLONMETER.COM • WEBSITE WWW.CARLONMETER.COM

CONTROLLER SELECTION CHART

MODEL	DESCRIPTION	WEIGHT	HEIGHT	DEPTH	WIDTH
PPC5001	SINGLE COUNTER & TIMER	2.0 LBS	3½"	5"	5"
PPC5002	DUAL COUNTER & TIMERS	2.1 LBS	3½"	5"	5"
PPC5003	TRIPLE COUNTER & TIMERS	2.4 LBS	3½"	5"	7"

SPECIFICATIONS

Dry Contact normally open switch closure activates Timer(s).

Display:	LCD (Liquid Crystal Display)
Input Power:	120V, 60 Cycle
Output Signal:	120V, 60 Cycle, 3 Amp Maximum
Enclosure:	NEMA 4
Timing Range:	1 to 999 Seconds or Minutes

Installation Instructions:

1. Install the control in the desired location, noting accessibility to power outlets. Mount and keep unit in an area free from dust, moisture, and extreme temperatures. (Do not plug in at this time). Remove dust cover with thumb screws. Use corner holes as mounting template (*mounting screws not provided).
2. Connect the meter input pigtail to the terminal screws on the water meter register. No polarity needs to be observed.
3. Plug in chemical pump(s) and/or solenoid valve to the short female output receptacle(s) 120 volt, 60 cycle outlet.
4. Plug the power cord into 120 volt outlet.
5. Refer to Programming Manual to program the Counter(s) and the Timer(s).

Warranty: Carlon Meter, Inc. warrants its products to be free of defect in material or workmanship for a period of twelve months from the date of purchase. Contact us to obtain a copy of our complete statement of warranty.